



INSTRUMENT CALIBRATION REPORT

Location:	Kentrol Inc., Winslow, ME
Test Date:	6-Mar-08
Kentrol Sales Order No.:	9682399
Customer Purchase Order No.:	437120
Controlling Document:	N/A
Transmitter Tag/ID:	FT-4030
Manufacturer:	Rosemount
Model Number:	3051S2CG2A2A11A1AM5
Maximum Range:	-250 TO 250 IN H2O
Input Range:	0-100 IN H2O
Specified Output Range:	4-20mA DC

Test Apparatus:	Make	Model	Cert/RA Number
Test Milliamp Source:	Multimeter Rosemount	Fluke 787 Hart 275	11-V687K-1-1 N/A

Test Results

Test No.	Test Source INCHES H2O	As Found Output (mAmps DC)	Inaccuracy %
1	0.00	3.998	-0.05
2	25.01	8.002	-0.01
3	50.14	12.024	-0.08
4	75.50	16.078	-0.18
5	100.13	20.032	-0.03
Average Overall Inaccuracy:			-0.07

Tested By: Gary Jackson
 Kentrol, Inc.
 Winslow, ME